




The State of New Hampshire  
***Department of Environmental Services***



**Michael P. Nolin**  
Commissioner

**LETTER OF DEFICIENCY**

No. WD SS 06-006

June 12, 2006

Ms. Chris Doetch  
491 Governor Wentworth Highway  
Melvin Village, NH 03850

RE: Movement of Septic Vent Pipe, CA2005074205

Dear Ms. Doetch:

On or about February 15, 2006, personnel from the Department of Environmental Services, Water Division ("DES") conducted an inspection of the above-referenced property, described as Lot # 4, on Tax Map # 14-2, and located on Governor Wentworth Highway, Melvin Village, NH, 03850 ("the Property"). The purpose of this inspection was to determine whether you were in compliance with RSA 485-A and its implementing regulations, the Subdivision and Individual Sewage Disposal System Design Rules, Env-Ws 1000 ("the Rules").

As a result of the inspection, the following deficiency was noted:

1. The vent pipe for the septic system has been moved from the position over the septic system approved on the approved septic construction plan.

DES believes the above deficiency can be permanently corrected within 15 days by initiating and completing the following measures:

1. Move the vent pipe for the system back to its original position as approved by DES.
2. Operate and maintain the system in accordance with NH Administrative Rule Env-Ws 1023.

DES believes the cited deficiencies can be corrected within 15 days and a report describing the corrective measures can be submitted to this office within 15 days of receipt of this letter.

In the event compliance is not achieved within this period, DES may initiate further action against you, including issuing an order requiring the above items to be corrected and/or referring the matter to the New Hampshire Department of Justice for imposition of civil and/or criminal penalties. DES reserves the right to pursue administrative fines for the violation(s) noted above.

The written report as requested above should be addressed as follows:

Richard J. de Seve, SSB, DES  
Department of Environmental Services  
6 Hazen Drive, PO Box 95  
Concord, NH 03302-0095

Your prompt cooperation is appreciated. Should you have any questions regarding this letter, please contact Richard J. de Seve at 271-3442.

Sincerely,



William E. Evans, P.E.  
Administrator  
Subsurface Systems Bureau

WEE/RJD

**CERTIFIED MAIL 7099 3400 0002 9772 9868**

Cc: James G. Falicon, SSB, DES  
Gretchen Hamel, Administrator, DES Legal Unit ✓  
Board of Selectmen, Town of Tuftonboro  
Richard J. de Seve, SSB, DES